



January 31, 2020

CERTIFIED MAIL 9214-8969-0099-9790-1416-6861-06

Mr. Adam Delk, VP of SC Operations
Palmetto Wastewater Reclamation, LLC
1710 Woodcreek Farms Road
Elgin, South Carolina, 29045-8755

Re: Notice of Violation 185203
Alpine Utilities/Stoop Creek WWTP
NPDES Permit SC0029483
Lexington County

Dear Mr. Delk:

A review of the discharge monitoring reports (DMRs) submitted to the Department for the September 2019 through October 2019 monitoring period has revealed the following violations:

PIPE #	PARAMETER	DATE	LIMIT	DMR	AVG/MAX
001	51040 E. COLI	10/31/2019	126	1120	LCAV
001	51040 E. COLI	10/31/2019	349	1120	LCMX


In addition to the October 2019 effluent violations, the required frequency of analysis for total residual chlorine was not met during the September 2019 monitoring period.

You are hereby notified that failure to comply with the requirements of the NPDES Permit is a violation of the Pollution Control Act, S.C. Code Ann. 48-1-110(d) (Supp. 2019) and Water Pollution Control Permits, 3 S.C. Code Ann. Regs. 61-9.122.41(a) (Supp. 2019). The violations make Palmetto Wastewater Reclamation, LLC subject to further enforcement action, which may include assessment of civil penalties as set forth in the Pollution Control Act, S.C. Code Ann. 48-1-330 (2008).

Since explanations for the violations cited were included with the monthly DMRs, a written response to this Notice of Violation is not required at this time. These explanations, however, will not relieve Palmetto Wastewater Reclamation, LLC of responsibility for the violations cited.

If you have any questions concerning this notice, you may call me at 803-898-4246. I will be glad to assist you.

Sincerely,


Melanie Hindman
Environmental Quality Manager
Bureau of Water

cc: Midlands, Columbia EQC Office